

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT		1. CONTRACT ID CODE		PAGE 1 OF 2 PAGES	
2. AMENDMENT/MODIFICATION NO. 0004		3. EFFECTIVE DATE 29 Jun 2023		4. REQUISITION/PURCHASE REQ. NO.	
5. PROJECT NO. (If applicable)		6. ISSUED BY CODE N69450		7. ADMINISTERED BY (If other than Item 6) CODE	
NAVAL FACILITIES ENGINEERING COMMAND SOUTHEAST CORE CONSTRUCTION, BUILDING 903, YORKTOWN NAVAL AIR STATION JACKSONVILLE, FL 32212-0030		NAVFAC SE PWD New Orleans Bldg. 552 Bloski Avenue, NAS JRB New Orleans, Belle Chase, LA 70143			
8. NAME AND ADDRESS OF CONTRACTOR (No. Street, county, State and ZIP: Code) 2021 West AO Multiple Award Construction Contract (MACC) N69450-21-D-0064/0065/0066/0067/0068/0069/0070 and N69450-22-D-0025/0026				(X) 9A. AMENDMENT OF SOLICITATION NO. N69450-23-R-DC18	
				X 9B. DATED (SEE ITEM 11) April 27, 2023	
				10A. MODIFICATION OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning one (1) copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATA SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and data specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

A.	THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
B.	THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
C.	THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
D.	OTHER Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not, ☒ is required to sign this document and return (1) copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

NOLA P520 DISTRIBUTION SWITCHGEAR NAVAL AIR STATION, JOINT RESERVE BASE, NEW ORLEANS, LOUISIANA

See Page 2

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		BY (Signature of Contracting Officer)	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

The purpose of this amendment is to:

1. Revise RFP, SECTION 00100 – INSTRUCTIONS TO OFFERORS, SECTION III, PROJECT INFORMATION

DELETE:

The general scope of this requirement is to provide backup power to the base when needed and help increase the life of the existing distribution switchgear. The new 15KV switchgear will be located in a secure area of the base, which will increase hardening of the electrical system. ~~The new switchgear will be configured to allow up to (2) generators to connect via new manual transfer switching.~~ At the end of the project, the existing switchgear will be demolished and the circuit feeders from this location removed to the nearest connection point. The new switchgear will be required to be elevated 3 feet above grade for flood protection.

REPLACE WITH:

The general scope of this requirement is to provide backup power to the base when needed and help increase the life of the existing distribution switchgear. The new 15KV switchgear will be located in a secure area of the base, which will increase hardening of the electrical system. **New site work includes installation of a new control house to house the new switchgear and new electrical service feeders.** At the end of the project, the existing switchgear will be demolished and the circuit feeders from this location removed to the nearest connection point. The new switchgear will be required to be elevated 3 feet above grade for flood protection.

Proposal submission due date remains at 3:00 PM Eastern Time on July 6, 2023.

ACKNOWLEDGEMENT OF THIS AMENDMENT IS REQUIRED WITH YOUR PROPOSAL SUBMISSION.

All other solicitation terms and conditions remain unchanged.